

CERTIFICATE

KEMA No.: 2114339.01

Issued to:
Applicant:

Lamp 83
Yahya Kemal Mahallesi
34410, KAGITHANE/ISTANBUL, Turkey

Manufacturer/Licensee:

Lamp 83
Yahya Kemal Mahallesi
34410, KAGITHANE/ISTANBUL, Turkey

Products : Recessed luminaires with fluorescent lamps
Trade name : LAMP83
Types : L DL7003001, L DL8003001, L DL9003001

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

KEMA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standards EN 60598-1:2004 and EN 60598-2-2:1996
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2114339

KEMA hereby grants the right to use the ENEC KEMA-KEUR certification mark.

The ENEC KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the ENEC KEMA-KEUR certification agreement and under the conditions of the ENEC KEMA-KEUR certification agreement.

This certificate is issued on: November 6, 2008 and expires upon withdrawal of one of the above mentioned standards.

KEMA Quality B.V.



drs. G.J. Zoetbrood
Managing Director



J. Bronsvort
Certification Manager

ACCREDITED BY
THE DUTCH COUNCIL
FOR ACCREDITATION



© Integral publication of this certificate is allowed

SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	:	recessed luminaires with fluorescent lamps
trade name	:	LAMP83
types	:	L DL7003001 L DL8003001 L DL9003001
rated voltage	:	230 V
nature of supply	:	ac
rated frequency	:	50 Hz
rated input	:	see product data per type
lamp type	:	see product data per type
class	:	I
degree of protection	:	IP20
description	:	recessed downlight luminaires for fluorescent lamps

Additional information

- luminaires are provided with F-marking.

Product data - type L DL7003001

rated input	:	1 x 13 W, 1 x 18 W, 1 x 26 W, 2 x 13 W, 2 x 18 W, 2 x 26 W
lamp type	:	TC-D/E

Product data - type L DL8003001

rated input	:	1 x 13 W, 1 x 18 W, 1 x 26 W, 1 x 32 W, 2 x 13 W, 2 x 18 W, 2 x 26 W, 2 x 32 W,
lamp type	:	TC-D/E and TC-T/E

Product data - type L DL9003001

rated input	:	1 x 18 W, 1 x 26 W, 1 x 32 W, 1 x 42 W, 2 x 18 W, 2 x 26 W, 2 x 32 W, 2 x 42 W
lamp type	:	TC-D/E and TC-T/E

TESTS**Test requirements**

EN 60598-1:2004 + A1:2006
EN 60598-2-2:1996 + A1:1997

Test result(s)

The test results are laid down in KEMA test file 2114339.01.

Remarks

This certificate supersedes the previous version of this certificate dated June 12, 2008, due to extension of the rated input possibilities of the various types.

Conclusion

The examination proved that all test requirements were met.

Tested by : H.J. Brouwer

Checked by : P.G.M. Roelofs

Two handwritten signatures in black ink. The first signature is for H.J. Brouwer and the second is for P.G.M. Roelofs. The signatures are written over the printed names.**Factory location**

Lamp 83,
Yahya Kemal Mahallesi, 34410, KAGITHANE/ISTANBUL, Turkey